

試驗報告

報告編號：TK-12-00003X

頁數：1 OF 2

報告日期：101 年 01 月 11 日

喬城實業有限公司

我們根據客戶送交之樣品逐一進行測試，結果如下：

產品名稱： 200 型玻璃爪具(#316)

送樣日期： 101 年 01 月 02 日



試驗日期： 101 年 01 月 02 日~101 年 01 月 10 日

測試要求： 抗壓試驗、抗拉試驗、成份分析

測試方法： 依客戶指定方式如相片所示，均勻施加荷重執行抗壓、抗拉測試(測試速率：10mm/min)、CNS 10006(1984)

測試結果：

抗壓試驗



試件名稱	顧客指定抗壓荷重	對應變形量	破壞情形
----	kgf	mm	----
爪具	205	1.8	爪具變形
	398	3.0	爪具變形
	607	3.9	爪具變形
	798	4.9	爪具變形
	1000	12.8	爪具變形

----- 1 -----

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested. This test report cannot be reproduced, except in full, without prior written permission of the Company. 除非另有說明，此報告結果僅對測試之樣品負責。本報告未經本公司書面許可，不可部份複製。

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

試驗報告

報告編號：TK-12-00003X

頁數：2 OF 2

報告日期：101 年 01 月 11 日

測試結果：

抗拉試驗



試件名稱	最大抗拉荷重	破壞情形
----	kgf	----
駁接頭	1800	轉動軸心無法旋轉

成份分析

試件名稱	C	Si	S	P	Mn	Ni	Cr	Mo
----	%	%	%	%	%	%	%	%
爪具	0.03	1.12	0.004	0.035	0.96	10.04	16.92	2.01

-----oOo-----

報告簽署人

本報告若有提供規範值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

Unless otherwise stated the results shown in this test report refer only to the sample(s) tested. This test report cannot be reproduced, except in full, without prior written permission of the Company. 除非另有說明，此報告結果僅對測試之樣品負責。本報告未經本公司書面許可，不可部份複製。

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at www.sgs.com/terms_e-document.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

TWA 6417478

Laboratory Testing · ISO Certification · Inspection
No. 9, 14th Rd., Taichung Industrial Park,
Taichung 40755, Taiwan, R.O.C.
Tel : (04) 23591515 (代表號)
Fax : (04) 23592557

PAGE NO 1
REPORT NO: TK-12-00003X



材料暨工程實驗室-台中

試驗報告



報告編號:TK-18-02590

頁次:1 OF 1

報告日期:107年05月18日

工程名稱: 中臺灣影視基地新建工程-採光罩
承包商: 聖典有限公司
委託單位: 聖典有限公司
樣品名稱: 不銹鋼玻璃爪具
送驗人員: 聖典有限公司-王清男
收件日期: 107年05月16日
試驗日期: 107年05月16日~107年05月18日
試驗方法: CNS 10006(1984)
備註: 1.以上資料由顧客提供(收件及試驗日期除外)
2.除非另有說明,此報告結果僅對測試之樣品負責
未經本公司事先書面同意,此報告不可部分複製

試驗結果:

成份分析

試件名稱	C	Si	S	P	Mn	Ni	Cr
----	%	%	%	%	%	%	%
不銹鋼玻璃爪具	0.06	0.55	0.006	0.025	0.61	8.17	17.07

----- oOo -----

本報告若有提供規範值時,該規範值僅供參考,合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Documents.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.



材料及工程實驗室-台中

試驗報告

報告編號: IS-07-02887X

頁數: 1 OF 1

報告日期: 96年 06月 06日

工程名稱: 中央研究院化學研究所後棟增建工程

委託單位: 宸鉉企業社

承包商: 宸鉉企業社

供料廠商: 朝良金屬有限公司

樣品名稱: 玻璃扣件(夾合部位)

送驗人員: 朝良金屬有限公司-謝朝祥

收件日期: 96年 06月 06日

試驗日期: 96年 06月 06日

試驗方法: CNS 10006(1984)

備註: 以上資料由送驗人員提供(試驗日期除外)

試驗結果:

試驗項目/試件編號	玻璃扣件(夾合部位)	CNS 3270 304類 要求
化學成份分析 %		
碳 C	0.06	0.09 以下
矽 Si	0.80	1.05 以下
硫 S	0.004	0.035 以下
磷 P	0.034	0.045 以下
錳 Mn	0.93	2.04 以下
鎳 Ni	8.03	7.85-10.65
鉻 Cr	18.46	17.80~20.20

備註1: 產品規範: CNS 3270 SUS304(2006)/CNS3158(1982)

2: 本試驗報告依據CNS 3270(2006)要求, 已加入CNS 3158(1982)製品許可差

----- ○ ○ ○ -----

本報告若有提供規範值時, 該規範值僅供參考, 合格之判定以委託單位實際要求為準。

This Test Report is issued by the Company subject to its General Conditions of Service printed overleaf or available on request and accessible at www.sgs.com. Attention is drawn to the limitations of liability, indemnification and jurisdictional issues defined therein. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested. This test report cannot be reproduced, except in full, without prior written permission of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this report is unlawful and offenders may be prosecuted to the fullest extent of the law. 此報告是遵循本公司訂定之通用服務條款所製作發放, 請注意此條款列印於背面, 亦可在www.sgs.com中查閱。將本公司之義務, 免責, 管轄權皆明確規範之。除非另有說明, 此報告結果僅對檢驗之樣品負責。本報告未經本公司書面許可, 不可部份複製。對本報告內容或外觀之任何未經授權之變更、偽造、竄改皆屬非法, 違犯者將會被依法追訴。

報告簽署人

FW 4300627

SGS Taiwan Ltd.
台灣檢驗科技股份有限公司

No. 115, Youyuan N. Rd.,
Lungjing Shiang, Taichung County, Taiwan.
t (886-4) 2631-1838

f (886-4) 2631-1990

www.tw.sgs.com

Member of SGS Group